AWWA Water Audit Level 1 Validation

Water System Name: Nevada Irrigation District Water System ID Number: 3110026/North Auburn Water Audit Period: 2018

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

In 2018 the District started replacing AMR meters with AMI meters and anticipates the complete replacement within five years. NID along with neighboring agencies, will work together to ensure that all import and export meters are calibrated and working properly. In those areas where there is no meter, NID staff will work to make sure that all imported/exported water is accurately accounted for.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, Water Audits and Loss Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5.

Greg Jones Interim General Manager

Executive Name (Print) Executive Position Signature Date



AWWA Water Audit Level 1 Validation – Review Document

Audit Information:

Utility: Nevada Irrigation District – North Auburn PWS ID: 3110026

System Type: Potable Audit Period: Validation conducted for Calendar Year Audits 2018 and 2019

Utility Representation: Aurora Tipton, Kaycee Strong

Validation Date: 2/3/2021 Call Time: 10:00am PT Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics for CY2018: Key Audit Metrics for CY2019:

Data Validity Score: 65 Data Validity Band (Level): Band III (51-70)

Data Validity Score: 65 Data Validity Band (Level): Band III (51-70)

ILI: 0.30 Real Loss: 6.45 (gal/conn/day) ILI: 0.74 Real Loss: 18.47 (gal/conn/day)

Apparent Loss: 15.01 (gal/conn/day)

Apparent Loss: 14.49 (gal/conn/day)

NRW as percent of cost of operating system: 0.8%

NRW as percent of cost of operating system: 0.5%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ⊠

Validator Information:

Water Audit Validator: Will Jernigan, P.E. Validator Qualifications: WAV Certified